

# MONOSPLIT HYPER

## Ceiling



- Ideal for very large environments, thanks to the particularly wide air flow
- **100 m** Split length
- Versatile installation thanks to drain pipe and refrigerant flexibility
- Polypropylene filter included

FDE 71-100-125-140 VH

Indoor unit model			FDE 71 VH	FDE 100 VH	FDE 125 VH	FDE 140 VH
Outdoor unit model			FDC 71 VNX-W	FDC 100 VSX-W	FDC 125 VSX-W	FDC 140 VSX-W
Type			DC-Inverter heat pump			
<b>Nominal data</b>						
Rated capacity (T <sub>in</sub> =+35°C)	Cooling	kW	7.10 (3.20~8.00)	10.00 (3.50~11.20)	12.50 (3.50~14.00)	14.00 (3.50~16.00)
Rated absorbed power (T <sub>in</sub> =+35°C)		kW	1.87	2.33	3.34	4.08
Rated energy efficiency coefficient		EER <sup>1</sup>	3.80	4.29	3.75	3.43
Rated capacity (T <sub>in</sub> =+7°C)	Heating	kW	8.00 (3.60~9.00)	11.20 (2.70~16.00)	14.00 (2.70~18.00)	16.00 (2.70~20.00)
Rated absorbed power (T <sub>in</sub> =+7°C)		kW	1.87	2.52	3.74	4.41
Rated energy performance coefficient		COP <sup>1</sup>	4.28	4.45	3.74	3.63
<b>Seasonal data</b>						
Theoretical load (P <sub>designc</sub> )	Cooling	kW	7.10	10.00	12.50	14.00
Seasonal energy efficiency index		SEER <sup>2</sup>	6.58	7.00	6.53	6.29
Seasonal energy efficiency class		626/2011 <sup>3</sup>	A++	A++	-	-
Annual energy consumption		kWh/a	378	501	-	-
Theoretical load (P <sub>designh</sub> ) @-10°C	Heating (average climate conditions)	kW	6.00	11.20	14.00	16.00
Seasonal energy efficiency index		SCOP <sup>2</sup>	4.45	4.24	4.02	3.96
Seasonal energy efficiency class		626/2011 <sup>3</sup>	A+	A+	-	-
Annual energy consumption		kWh/a	1889	3700	-	-
<b>Electrical data</b>						
Power supply	Outdoor unit	Ph-V-Hz	1-220~240V-50Hz		3-380~415V-50Hz	
Power cable		Type	3 x 4 mm <sup>2</sup>		5 x 4 mm <sup>2</sup>	
Connection wires between I.U. and O.U.		no.	4		4	
Absorbed current	Cooling	A	8.30		5.40	
	Heating	A	8.30		6.10	
Maximum current		A	19.10		14.00	
Maximum absorbed power		kW	4.11		8.90	
<b>Refrigerant circuit</b>						
Refrigerant <sup>4</sup>		Type (GWP)	R32 (675)			
Quantity refrigerant pre-load		Kg	2.75		4	
Tons of CO <sub>2</sub> equivalent		t	1.856		2.700	
Diameter of refrigerant piping on liquid/gas		mm (inches)	ø9.52 (3/8") - ø15.88(5/8")		ø9.52 (3/8") - ø15.88(5/8")	
Max splitting length	Min/Max	m	3/50		3/100	
Max height difference I.U./O.U.	O.U. above/O.U. under	m	30/15		50/15	
Split length without additional charge		m	30		30	
Additional load		g/m	54		54	
<b>Indoor unit specifications</b>						
Dimensions	LxDxH	mm	1320x690x210		1620x690x250	
Net weight		Kg	33		43	
Sound power level	Max	dB(A)	60		64	
Sound pressure level	P-Hi/Hi/Me/Lo	dB(A)	47/41/37/32		48/43/38/34	
Treated air volume	P-Hi/Hi/Me/Lo	m <sup>3</sup> /h	1200/960/780/600		1920/1560/1260/990	
<b>Outdoor unit specifications</b>						
Dimensions	LxDxH	mm	880(+88)x340x750		970x370x1300	
Net weight		Kg	60		99	
Sound power level	Max	dB(A)	66		70	
Sound pressure level	Max	dB(A)	51		53	
Treated air volume	Max	m <sup>3</sup> /h	3600		6000	
Operating limits (outside temperature)	Cooling	°C	-15~+50			
	Heating	°C	-20~+20			
<b>Accessories</b>						
Wired remote control	RC-E5 (LCD) / RC-EX3A (touch) / RCH-E3 (simplified)					
IR remote control (KIT)	RCN-E-E3					
<b>Optional parts</b>						
Wi-Fi module	INWFIMH1001R000					
Human sensor (KIT)	LB-E					
SUPERLINK II interface	SC-ADNA-E					

1. Value measured according to the harmonised standard EN 14511. 2. EU Regulation No. 206/2012 - Value measured according to the harmonised standard EN 14825. 3. Delegated Regulation (EU) No 626/2011 regarding the new energy labelling of air conditioners. 4. Refrigerant leakage contributes to climate change. When released into the atmosphere, refrigerants with a lower global warming potential (GWP) contribute less to global warming than those with a higher GWP. This appliance contains a refrigerant with a GWP of 675. If 1 kg of this refrigerant fluid were released into the atmosphere, therefore, the impact on global warming would be 675 times higher than 1 kg of CO<sub>2</sub>, over a period of 100 years. Under no circumstances should the user try to intervene on the refrigerant circuit or disassemble the product. Always contact qualified personnel if necessary.