MONOSPI IT SMART

COLUMN R32

FDF 71-100 VH





 Ideal for restaurants, shops and officies applications, without false ceiling or high ceilings

■ 25 m

Splitting distance

- Wide and powerful air flow
- Easy transport and installation
- The wired control has a alarm function in case of gas leakage. The gas sensor is on the base of the unit

Indoor unit model			FDF 71 VH	FDF 100 VH	FDF 100 VH
				FDC 90 VNP-W	
Outdoor unit model			FDC 71 VNP-W		FDC 100 VNP-W
Type			DC-Inverter heat pump		
Control (included)			Wired control TOUCH with gas leak alarm		
Nominal data		LAA	7.10 (1.50	0.00 (2.10, 0.50)	10.00 (2.10, 10.20)
Rated capacity (T=+35°C)	Cooling	kW	7.10 (1.50~7.30)	9.00 (2.10~9.50)	10.00 (2.10~10.20)
Rated power input (T=+35°C)		kW FFR1	2.51	2.5	3.39
Rated energy efficiency coefficient			2.82		2.95
Rated capacity (T=+7°C)	Heating	kW kW	7.10 (1.10~7.30)	9.00 (1.70~9.50)	10.00 (1.70~10.40)
Rated power input (T=+7°C)		COP1	2.02	2.24	2.71
Rated energy performance coefficient			3.51	4.02	3.69
Seasonal data					
Design load (Pdesignc)		kW	7.10	9.00	10.00
Seasonal energy efficiency index	Cooling	SEER2	5.85	5.91	5.43
Seasonal energy efficiency class		626/20113	A+	A+	Α
Annual energy consumption		kWh/y	425	535	645
Design load (Pdesignh) @ -10°C	Heating (average climate conditions)	kW	5.70	6.00	6.40
Seasonal energy efficiency index		SCOP2	3.91	4.24	3.94
Seasonal energy efficiency class		626/20113	A	A+	A
Annual energy consumption		kWh/y	2039	1981	2274
Electrical data					
Power supply	Outdoor unit	Ph-V-Hz		1-220~240V-50Hz	
Power cable		Type	3 x 4 mm ²	3 x 4 mm ²	3 x 4 mm ²
Connection wires between I.U. and O.U.		nb.	4	4	4
Naminal absorbed current	inal absorbed current Cooling Heating	A	11.10	11.10	15.00
Norminal absorbed current		A	9.10	9.90	12.00
Maximum current		A	15.80	19.00	19.00
Max power input		kW	3.58	4.46	4.46
Refrigerant circuit data					
Refrigerant ⁴		Type (GWP)		R32 (675)	
Quantity of refrigerant pre-charge		Kg	1.3	1.7	1.7
Tons of CO2 equivalent		t	0.878	1.148	1.148
Diameter of refrigerant pipings liquid/gas		mm (inches)	ø6.35(1/4") - ø12.7(1/2")	ø6.35 (1/4") - ø15.88 (5/8")	ø6.35 (1/4") - ø15.88 (5/8")
Splitting distance		m	26	25	25
Splitting level difference I.U./O.U.		m	20	20	20
Splitting distance without additional charge		m	11	10	10
Additional charge		g/m	20	20	20
Indoor unit specifications				<u>'</u>	
Dimensions	LxDxH	mm	600x329x1850	600x329x1850	600x329x1850
Net weight		Kg	47	49	49
Sound power level	Max	dB(A)	55	65	65
Sound pressure level	P-Hi/Hi/Me/Lo	dB(A)	42/39/35/33	53/51/49/44	53/51/49/44
Volume of air treated	P-Hi/Hi/Me/Lo	m³/h	1080/960/840/720	1620/1560/1380/1140	1620/1560/1380/1140
Refrigerant gas leak detector	, , , , , , , , , , , , , , , , , , , ,			INCLUDED	
Outdoor unit specifications				23020	
Dimensions	LxDxH	mm	800(+71)x290x640	800(+71)x340x750	880(+88)x340x750
Net weight	1	Kg	45	57	57
Sound power level	Max	dB(A)	67	67	68
Sound pressure level	Max	dB(A)	54	55	56
Volume of air treated	Max	m³/h	2520	3540	3780
	Cooling	°C	2,520	-15~+46	5700
Operating range (outdoor temperature) Heating °C			-15~+20		
Optional parts					
Wi-Fi module			INWFIMHI001R100		
Human sensor (KIT)			LB-KIT2		
SUPERLINK II interface			SC-ADNA-E		
SUPERLINK II interface				JC-NUINN-L	

^{1.} Value measured according to the harmonised standard EN 14511. 2. EU Regulation No. 206/2012 - - Value measured according to the harmonised standard EN 14825. 3. Delegated Regulation (EU) No 626/2011 reparding the new energy labelling of air conditioners. 4. Refrigerant leakage contributes to climate change. When released into the atmosphere, refrigerants with a lower global warming potential (GWP) contribute less to global warming than those with a higher GWP. This appliance contains a refrigerant with a GWP of 675. If 1 kg of this refrigerant fluid were released into the atmosphere, therefore, the impact on global warming would be 675 times higher than 1 kg of CO2, over a period of 100 years. Under no circumstances should the user try to intervene on the refrigerant circuit or disassemble the product. Always contact qualified personnel if necessary.

